

# Evaluating Baselines for Demand Response Programs

**Presented to the AEIC Load Research Workshop**

**February 25-27, 2008**

**San Antonio, Texas**

**By Clifford Grimm - DTE Energy**

**DTE Energy**



- **Introduction**
- **Definitions**
- **What is a baseline?**
- **Parameters**
- **Methodologies**
- **Conclusions**

## Introduction




**Baselines refer to customer energy usage absent any outside influences to change that usage such as high temperatures that can influence air conditioning usage. Baselines may be used to measure the effectiveness of demand response programs by analyzing the difference between a customers' baseline energy usage and the energy the customer actually used.**

## Definitions

- **Demand response event** – A specific time period on a specific day.
- **Actual Use** – The amount of energy the customer *actually consumed* during the event period.
- **Load Reduction** – The mathematical difference between the baseline and the actual use.

# What is a baseline?

- **Baseline** – The amount of energy the customer would have consumed absent a request to reduce.




## Parameters

- **Single Set of Data**
  - **May through September 2006**
  - **Residential sample mean values**
- **Event Day**
  - **Wednesday in August**
  - **95°F maximum temperature**
  - **Event period – 12:00 noon to 8:00pm**
- **Load Reduction Levels**
  - **10%, 20%, 30%**



## Methodologies

- **ISO New England**
- **New York ISO**
- **California ISO**
- **PJM**
- **+90°F Average Day**



## ISO New England

- **New Customer**
  - New to demand response program
  - Average of 5 business days (Monday – Friday, no holidays, no event days)
  - Hourly metered data averaged by hour for 5 business days
- **Current Customer**
  - Has baseline calculated before
  - Previous day baseline + current day meter data
  - Weighting factors
- **Adjustment Provision**
  - Average of 2 hours before event starts
  - Apply to 2 hours before and entire event




# ISO New England – Applying Baseline to Demand Response

Hour	Actual Customer Load	Customer Load			Calculated Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.31	0.39	0.39	0.39
2	1.60	1.60	1.60	1.60	1.18	0.42	0.42	0.42
3	1.50	1.50	1.50	1.50	1.08	0.42	0.42	0.42
4	1.30	1.30	1.30	1.30	1.02	0.28	0.28	0.28
5	1.30	1.30	1.30	1.30	0.98	0.32	0.32	0.32
6	1.30	1.30	1.30	1.30	1.00	0.30	0.30	0.30
7	1.30	1.30	1.30	1.30	1.03	0.27	0.27	0.27
8	1.30	1.30	1.30	1.30	1.14	0.16	0.16	0.16
9	1.40	1.40	1.40	1.40	1.18	0.22	0.22	0.22
10	1.60	1.60	1.60	1.60	1.29	0.31	0.31	0.31
11	1.70	1.70	1.70	1.70	1.36	0.34	0.34	0.34
12	1.90	1.71	1.52	1.33	1.45	<b>0.26</b>	<b>0.07</b>	<b>(0.12)</b>
13	1.90	1.71	1.52	1.33	1.59	<b>0.12</b>	<b>(0.07)</b>	<b>(0.26)</b>
14	2.10	1.89	1.68	1.47	1.71	<b>0.18</b>	<b>(0.03)</b>	<b>(0.24)</b>
15	2.20	1.98	1.76	1.54	1.80	<b>0.18</b>	<b>(0.04)</b>	<b>(0.26)</b>
16	2.30	2.07	1.84	1.61	1.89	<b>0.18</b>	<b>(0.05)</b>	<b>(0.28)</b>
17	2.30	2.07	1.84	1.61	1.96	<b>0.11</b>	<b>(0.12)</b>	<b>(0.35)</b>
18	2.30	2.07	1.84	1.61	2.01	<b>0.06</b>	<b>(0.17)</b>	<b>(0.40)</b>
19	2.40	2.16	1.92	1.68	2.10	<b>0.06</b>	<b>(0.18)</b>	<b>(0.42)</b>
20	2.40	2.16	1.92	1.68	1.98	<b>0.18</b>	<b>(0.06)</b>	<b>(0.30)</b>
21	2.30	2.30	2.42	2.47	1.92	0.38	0.50	0.56
22	2.40	2.40	2.52	2.58	2.00	0.40	0.52	0.58
23	2.30	2.30	2.42	2.47	1.91	0.39	0.51	0.57
24	2.00	2.00	2.10	2.15	1.62	0.38	0.48	0.53

# ISO New England – Applying Baseline to Demand Response



Demand Reduction Event Day  
New England Baseline Calculation





# ISO New England – Adjustment Calculation

Hour	Customer Load	New Baseline	Adjustment	Adjusted Baseline
1	1.70	1.31		1.31
2	1.60	1.18		1.18
3	1.50	1.08		1.08
4	1.30	1.02		1.02
5	1.30	0.98		0.98
6	1.30	1.00		1.00
7	1.30	1.03		1.03
8	1.30	1.14		1.14
9	1.40	1.18		1.18
10	1.60	1.29	0.325	1.62
11	1.70	1.36	0.325	1.69
12	1.33	1.45	0.325	1.77
13	1.33	1.59	0.325	1.92
14	1.47	1.71	0.325	2.03
15	1.54	1.80	0.325	2.12
16	1.61	1.89	0.325	2.21
17	1.61	1.96	0.325	2.29
18	1.61	2.01	0.325	2.33
19	1.68	2.10	0.325	2.42
20	1.68	1.98	0.325	2.31
21	2.47	1.92		1.92
22	2.58	2.00		2.00
23	2.47	1.91		1.91
24	2.15	1.62		1.62

Hour 10 -  $1.60 - 1.29 = .31$   
Hour 11 -  $1.70 - 1.36 = .34$   
Adjustment -  $.31 + .34 = .65 / 2 = .325$

Adjustment Period

# ISO New England – Applying Adjusted Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Adjusted Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.31	0.39	0.39	0.39
2	1.60	1.60	1.60	1.60	1.18	0.42	0.42	0.42
3	1.50	1.50	1.50	1.50	1.08	0.42	0.42	0.42
4	1.30	1.30	1.30	1.30	1.02	0.28	0.28	0.28
5	1.30	1.30	1.30	1.30	0.98	0.32	0.32	0.32
6	1.30	1.30	1.30	1.30	1.00	0.30	0.30	0.30
7	1.30	1.30	1.30	1.30	1.03	0.27	0.27	0.27
8	1.30	1.30	1.30	1.30	1.14	0.16	0.16	0.16
9	1.40	1.40	1.40	1.40	1.18	0.22	0.22	0.22
10	1.60	1.60	1.60	1.60	1.62	(0.02)	(0.02)	(0.02)
11	1.70	1.70	1.70	1.70	1.69	0.01	0.01	0.01
12	1.90	1.71	1.52	1.33	1.77	<b>(0.06)</b>	<b>(0.25)</b>	<b>(0.44)</b>
13	1.90	1.71	1.52	1.33	1.92	<b>(0.21)</b>	<b>(0.40)</b>	<b>(0.59)</b>
14	2.10	1.89	1.68	1.47	2.03	<b>(0.14)</b>	<b>(0.35)</b>	<b>(0.56)</b>
15	2.20	1.98	1.76	1.54	2.12	<b>(0.14)</b>	<b>(0.36)</b>	<b>(0.58)</b>
16	2.30	2.07	1.84	1.61	2.21	<b>(0.14)</b>	<b>(0.37)</b>	<b>(0.60)</b>
17	2.30	2.07	1.84	1.61	2.29	<b>(0.22)</b>	<b>(0.45)</b>	<b>(0.68)</b>
18	2.30	2.07	1.84	1.61	2.33	<b>(0.26)</b>	<b>(0.49)</b>	<b>(0.72)</b>
19	2.40	2.16	1.92	1.68	2.42	<b>(0.26)</b>	<b>(0.50)</b>	<b>(0.74)</b>
20	2.40	2.16	1.92	1.68	2.31	<b>(0.15)</b>	<b>(0.39)</b>	<b>(0.63)</b>
21	2.30	2.30	2.42	2.47	1.92	0.38	0.50	0.56
22	2.40	2.40	2.52	2.58	2.00	0.40	0.52	0.58
23	2.30	2.30	2.42	2.47	1.91	0.39	0.51	0.57
24	2.00	2.00	2.10	2.15	1.62	0.38	0.48	0.53

# ISO New England – Applying Adjusted Baseline to Demand Response




Demand Reduction Event Day  
New England Adjusted Baseline Calculation



## New York ISO

- **Step Process**
  - **Comparing daily energy to previous day energy (GT 25%)**
  - **Select 10 days (weekdays, no event or curtailment day)**
  - **Average 5 days w/ highest energy**
- **Adjustment Procedure**
  - **4 hours prior to event start**
  - **Average 2 hours**
  - **Apply to event only**

# New York ISO – Applying Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Calculated Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.17	0.53	0.53	0.53
2	1.60	1.60	1.60	1.60	1.04	0.56	0.56	0.56
3	1.50	1.50	1.50	1.50	0.96	0.54	0.54	0.54
4	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
5	1.30	1.30	1.30	1.30	0.87	0.43	0.43	0.43
6	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
7	1.30	1.30	1.30	1.30	0.95	0.35	0.35	0.35
8	1.30	1.30	1.30	1.30	1.04	0.26	0.26	0.26
9	1.40	1.40	1.40	1.40	1.04	0.36	0.36	0.36
10	1.60	1.60	1.60	1.60	1.16	0.44	0.44	0.44
11	1.70	1.70	1.70	1.70	1.22	0.48	0.48	0.48
12	1.90	1.71	1.52	1.33	1.28	0.43	0.24	0.05
13	1.90	1.71	1.52	1.33	1.42	0.29	0.10	<b>(0.09)</b>
14	2.10	1.89	1.68	1.47	1.57	0.32	0.11	<b>(0.10)</b>
15	2.20	1.98	1.76	1.54	1.63	0.35	0.13	<b>(0.09)</b>
16	2.30	2.07	1.84	1.61	1.73	0.34	0.11	<b>(0.12)</b>
17	2.30	2.07	1.84	1.61	1.83	0.24	0.01	<b>(0.22)</b>
18	2.30	2.07	1.84	1.61	1.85	0.22	<b>(0.01)</b>	<b>(0.24)</b>
19	2.40	2.16	1.92	1.68	1.95	0.21	<b>(0.03)</b>	<b>(0.27)</b>
20	2.40	2.16	1.92	1.68	1.84	0.32	0.08	<b>(0.16)</b>
21	2.30	2.30	2.42	2.47	1.74	0.56	0.68	0.74
22	2.40	2.40	2.52	2.58	1.79	0.61	0.73	0.79
23	2.30	2.30	2.42	2.47	1.69	0.61	0.72	0.78
24	2.00	2.00	2.10	2.15	1.43	0.57	0.67	0.72



# New York ISO – Applying Baseline to Demand Response

Demand Reduction Event Day  
New York Baseline Calculation





# New York ISO – Adjustment Calculation

Hour	Customer Load	Customer Baseline	Adjustment	Adjusted Baseline
1	1.70	1.17		1.17
2	1.60	1.04		1.04
3	1.50	0.96		0.96
4	1.30	0.90		0.90
5	1.30	0.87		0.87
6	1.30	0.90		0.90
7	1.30	0.95		0.95
8	1.30	1.04		1.04
9	1.40	1.04		1.04
10	1.60	1.16		1.16
11	1.70	1.22		1.22
12	1.33	1.28	1.30	1.66
13	1.33	1.42	1.30	1.85
14	1.47	1.57	1.30	2.04
15	1.54	1.63	1.30	2.12
16	1.61	1.73	1.30	2.25
17	1.61	1.83	1.30	2.38
18	1.61	1.85	1.30	2.40
19	1.68	1.95	1.30	2.53
20	1.68	1.84	1.30	2.39
21	2.47	1.74		2.25
22	2.58	1.79		1.79
23	2.47	1.69		1.69
24	2.15	1.43		1.43

} Adjustment Period


Customer Baseline Average of Hours 8&9  $(1.04 + 1.04)/2 = 1.04$   
 Customer Load Average of Hours 8&9  $(1.30 + 1.40)/2 = 1.35$   
 Adjustment  $1.35/1.04 = 1.30$

# New York ISO – Applying Adjusted Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Adjusted Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.17	0.53	0.53	0.53
2	1.60	1.60	1.60	1.60	1.04	0.56	0.56	0.56
3	1.50	1.50	1.50	1.50	0.96	0.54	0.54	0.54
4	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
5	1.30	1.30	1.30	1.30	0.87	0.43	0.43	0.43
6	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
7	1.30	1.30	1.30	1.30	0.95	0.35	0.35	0.35
8	1.30	1.30	1.30	1.30	1.04	0.26	0.26	0.26
9	1.40	1.40	1.40	1.40	1.04	0.36	0.36	0.36
10	1.60	1.60	1.60	1.60	1.16	0.44	0.44	0.44
11	1.70	1.70	1.70	1.70	1.22	0.48	0.48	0.48
12	1.90	1.71	1.52	1.33	1.66	0.05	(0.14)	(0.33)
13	1.90	1.71	1.52	1.33	1.85	(0.14)	(0.33)	(0.52)
14	2.10	1.89	1.68	1.47	2.04	(0.15)	(0.36)	(0.57)
15	2.20	1.98	1.76	1.54	2.12	(0.14)	(0.36)	(0.58)
16	2.30	2.07	1.84	1.61	2.25	(0.18)	(0.41)	(0.64)
17	2.30	2.07	1.84	1.61	2.38	(0.31)	(0.54)	(0.77)
18	2.30	2.07	1.84	1.61	2.40	(0.33)	(0.56)	(0.79)
19	2.40	2.16	1.92	1.68	2.53	(0.37)	(0.61)	(0.85)
20	2.40	2.16	1.92	1.68	2.39	(0.23)	(0.47)	(0.71)
21	2.30	2.30	2.42	2.47	2.25	0.05	0.16	0.22
22	2.40	2.40	2.52	2.58	1.79	0.61	0.73	0.79
23	2.30	2.30	2.42	2.47	1.69	0.61	0.72	0.78
24	2.00	2.00	2.10	2.15	1.43	0.57	0.67	0.72

# New York ISO – Applying Adjusted Baseline to Demand Response



Demand Reduction Event Day  
New York Customer Baseline Calculation w/ Weather Adjustment





## California ISO


- **3 Highest Energy Use Days from Past 10 Days (Monday-Friday, no holidays, event days, curtailment days, rotating outage days)**
- **Only Hydro Pump Customers now, different types in future**
- **No Adjustment to Baseline, yet**
  - **CPUC R.07-01-041**
  - **California ISO expects changes in future**

# California ISO – Applying Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Calculated Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.38	0.32	0.32	0.32
2	1.60	1.60	1.60	1.60	1.23	0.37	0.37	0.37
3	1.50	1.50	1.50	1.50	1.13	0.38	0.38	0.38
4	1.30	1.30	1.30	1.30	1.07	0.23	0.23	0.23
5	1.30	1.30	1.30	1.30	1.03	0.27	0.27	0.27
6	1.30	1.30	1.30	1.30	1.03	0.27	0.27	0.27
7	1.30	1.30	1.30	1.30	1.07	0.23	0.23	0.23
8	1.30	1.30	1.30	1.30	1.18	0.12	0.12	0.12
9	1.40	1.40	1.40	1.40	1.21	0.19	0.19	0.19
10	1.60	1.60	1.60	1.60	1.33	0.27	0.27	0.27
11	1.70	1.70	1.70	1.70	1.46	0.24	0.24	0.24
12	1.90	1.71	1.52	1.33	1.52	0.19	<b>(0.00)</b>	<b>(0.19)</b>
13	1.90	1.71	1.52	1.33	1.71	0.00	<b>(0.19)</b>	<b>(0.38)</b>
14	2.10	1.89	1.68	1.47	1.83	0.06	<b>(0.15)</b>	<b>(0.36)</b>
15	2.20	1.98	1.76	1.54	1.95	0.03	<b>(0.19)</b>	<b>(0.41)</b>
16	2.30	2.07	1.84	1.61	2.04	0.03	<b>(0.20)</b>	<b>(0.43)</b>
17	2.30	2.07	1.84	1.61	2.11	<b>(0.04)</b>	<b>(0.27)</b>	<b>(0.50)</b>
18	2.30	2.07	1.84	1.61	2.17	<b>(0.10)</b>	<b>(0.33)</b>	<b>(0.56)</b>
19	2.40	2.16	1.92	1.68	2.24	<b>(0.08)</b>	<b>(0.32)</b>	<b>(0.56)</b>
20	2.40	2.16	1.92	1.68	2.09	0.07	<b>(0.17)</b>	<b>(0.41)</b>
21	2.30	2.30	2.42	2.47	2.07	0.23	0.35	0.40
22	2.40	2.40	2.52	2.58	2.14	0.26	0.38	0.44
23	2.30	2.30	2.42	2.47	2.05	0.25	0.36	0.42
24	2.00	2.00	2.10	2.15	1.77	0.23	0.33	0.38

# California ISO – Applying Baseline to Demand Response




Demand Reduction Event Day  
California Baseline Calculation



- **Ratio Daily Energy to Previous Day Energy**
  - Discard if less than or equal to 75%
  - Select 10 days (weekdays, no event or curtailment day)
  - Average 5 highest energy days by hour
- **2 Adjustment Procedures**
  - **Average of Hour**
    - Summer and real-time market only
    - 4 Hours prior to event start
    - Average 2 hours
    - Apply to event only
    - Adjustment GT 5% to apply
  - **Regression Model**
    - Any market and any season

# PJM – Applying Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Calculated Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.20	0.50	0.50	0.50
2	1.60	1.60	1.60	1.60	1.06	0.54	0.54	0.54
3	1.50	1.50	1.50	1.50	0.98	0.52	0.52	0.52
4	1.30	1.30	1.30	1.30	0.91	0.39	0.39	0.39
5	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
6	1.30	1.30	1.30	1.30	0.91	0.39	0.39	0.39
7	1.30	1.30	1.30	1.30	0.96	0.34	0.34	0.34
8	1.30	1.30	1.30	1.30	1.04	0.26	0.26	0.26
9	1.40	1.40	1.40	1.40	1.06	0.34	0.34	0.34
10	1.60	1.60	1.60	1.60	1.20	0.40	0.40	0.40
11	1.70	1.70	1.70	1.70	1.27	0.43	0.43	0.43
12	1.90	1.71	1.52	1.33	1.32	0.39	0.20	0.01
13	1.90	1.71	1.52	1.33	1.46	0.25	0.06	(0.13)
14	2.10	1.89	1.68	1.47	1.62	0.27	0.06	(0.15)
15	2.20	1.98	1.76	1.54	1.69	0.29	0.07	(0.15)
16	2.30	2.07	1.84	1.61	1.77	0.30	0.07	(0.16)
17	2.30	2.07	1.84	1.61	1.86	0.21	(0.02)	(0.25)
18	2.30	2.07	1.84	1.61	1.89	0.18	(0.05)	(0.28)
19	2.40	2.16	1.92	1.68	1.97	0.19	(0.05)	(0.29)
20	2.40	2.16	1.92	1.68	1.84	0.32	0.08	(0.16)
21	2.30	2.30	2.42	2.47	1.74	0.56	0.67	0.73
22	2.40	2.40	2.52	2.58	1.80	0.60	0.72	0.78
23	2.30	2.30	2.42	2.47	1.70	0.60	0.71	0.77
24	2.00	2.00	2.10	2.15	1.44	0.56	0.66	0.71



# PJM – Applying Baseline to Demand Response

Demand Reduction Event Day  
PJM Baseline Calculation





# PJM – Adjustment Calculation

Hour	Customer Load	Calculated Baseline	Adjustment	Adjusted Baseline
1	1.70	1.20		1.20
2	1.60	1.06		1.06
3	1.50	0.98		0.98
4	1.30	0.91		0.91
5	1.30	0.90		0.90
6	1.30	0.91		0.91
7	1.30	0.96		0.96
8	1.30	1.04		1.04
9	1.40	1.06		1.06
10	1.60	1.20		1.20
11	1.70	1.27		1.27
12	1.71	1.32	1.33	1.76
13	1.71	1.46	1.33	1.94
14	1.89	1.62	1.33	2.16
15	1.98	1.69	1.33	2.25
16	2.07	1.77	1.33	2.35
17	2.07	1.86	1.33	2.47
18	2.07	1.89	1.33	2.52
19	2.16	1.97	1.33	2.62
20	2.16	1.84	1.33	2.45
21	2.30	1.74		1.74
22	2.40	1.80		1.80
23	2.30	1.70		1.70
24	2.00	1.44		1.44

Customer Baseline Average of Hours 9&10  
 Customer Load Average of Hours 9&10  
 Weather Adjustment Factor

$(1.06 + 1.20)/2 = 1.13$   
 $(1.40 + 1.60)/2 = 1.50$   
 $1.50/1.13 = 1.33 = 33\%$

}

Adjustment  
Period

# PJM – Applying Adjusted Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Adjusted Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.20	0.50	0.50	0.50
2	1.60	1.60	1.60	1.60	1.06	0.54	0.54	0.54
3	1.50	1.50	1.50	1.50	0.98	0.52	0.52	0.52
4	1.30	1.30	1.30	1.30	0.91	0.39	0.39	0.39
5	1.30	1.30	1.30	1.30	0.90	0.40	0.40	0.40
6	1.30	1.30	1.30	1.30	0.91	0.39	0.39	0.39
7	1.30	1.30	1.30	1.30	0.96	0.34	0.34	0.34
8	1.30	1.30	1.30	1.30	1.04	0.26	0.26	0.26
9	1.40	1.40	1.40	1.40	1.06	0.34	0.34	0.34
10	1.60	1.60	1.60	1.60	1.20	0.40	0.40	0.40
11	1.70	1.70	1.70	1.70	1.27	0.43	0.43	0.43
12	1.90	1.71	1.52	1.33	1.76	(0.05)	(0.24)	(0.43)
13	1.90	1.71	1.52	1.33	1.95	(0.24)	(0.43)	(0.62)
14	2.10	1.89	1.68	1.47	2.16	(0.27)	(0.48)	(0.69)
15	2.20	1.98	1.76	1.54	2.25	(0.27)	(0.49)	(0.71)
16	2.30	2.07	1.84	1.61	2.35	(0.28)	(0.51)	(0.74)
17	2.30	2.07	1.84	1.61	2.48	(0.41)	(0.64)	(0.87)
18	2.30	2.07	1.84	1.61	2.52	(0.45)	(0.68)	(0.91)
19	2.40	2.16	1.92	1.68	2.62	(0.46)	(0.70)	(0.94)
20	2.40	2.16	1.92	1.68	2.45	(0.29)	(0.53)	(0.77)
21	2.30	2.30	2.42	2.47	1.74	0.56	0.67	0.73
22	2.40	2.40	2.52	2.58	1.80	0.60	0.72	0.78
23	2.30	2.30	2.42	2.47	1.70	0.60	0.71	0.77
24	2.00	2.00	2.10	2.15	1.44	0.56	0.66	0.71



# PJM – Applying Adjusted Baseline to Demand Response

Demand Reduction Event Day  
PJM Adjusted Baseline Calculation





+90°F Average Day

- **May – September**
- **Weekdays (no holidays)**
- **Daily High Temperature 90°F or Higher**
- **No Adjustment Provision, but...**
  - **Used ISO New England**
  - **Same rationale**




# +90°F Average Day – Applying Baseline to Demand Response

Hour	Actual Customer Load	Customer Load			Calculated Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.56	0.14	0.14	0.14
2	1.60	1.60	1.60	1.60	1.45	0.15	0.15	0.15
3	1.50	1.50	1.50	1.50	1.31	0.19	0.19	0.19
4	1.30	1.30	1.30	1.30	1.22	0.08	0.08	0.08
5	1.30	1.30	1.30	1.30	1.18	0.12	0.12	0.12
6	1.30	1.30	1.30	1.30	1.17	0.13	0.13	0.13
7	1.30	1.30	1.30	1.30	1.18	0.12	0.12	0.12
8	1.30	1.30	1.30	1.30	1.25	0.05	0.05	0.05
9	1.40	1.40	1.40	1.40	1.34	0.06	0.06	0.06
10	1.60	1.60	1.60	1.60	1.50	0.10	0.10	0.10
11	1.70	1.70	1.70	1.70	1.64	0.06	0.06	0.06
12	1.90	1.71	1.52	1.33	1.74	(0.03)	(0.22)	(0.41)
13	1.90	1.71	1.52	1.33	1.88	(0.17)	(0.36)	(0.55)
14	2.10	1.89	1.68	1.47	2.03	(0.14)	(0.35)	(0.56)
15	2.20	1.98	1.76	1.54	2.15	(0.17)	(0.39)	(0.61)
16	2.30	2.07	1.84	1.61	2.20	(0.13)	(0.36)	(0.59)
17	2.30	2.07	1.84	1.61	2.22	(0.15)	(0.38)	(0.61)
18	2.30	2.07	1.84	1.61	2.33	(0.26)	(0.49)	(0.72)
19	2.40	2.16	1.92	1.68	2.38	(0.22)	(0.46)	(0.70)
20	2.40	2.16	1.92	1.68	2.31	(0.15)	(0.39)	(0.63)
21	2.30	2.30	2.42	2.47	2.22	0.08	0.19	0.25
22	2.40	2.40	2.52	2.58	2.34	0.06	0.18	0.24
23	2.30	2.30	2.42	2.47	2.24	0.06	0.18	0.23
24	2.00	2.00	2.10	2.15	1.87	0.13	0.23	0.28



# +90°F Average Day – Applying Baseline to Demand Response

Demand Reduction Event Day  
+90°F Average Day Baseline Calculation





# +90°F Average Day – Adjustment Calculation

Hour	Customer Load	New Baseline	Adjustment	Adjusted Baseline
1	1.70	1.56		1.56
2	1.60	1.45		1.45
3	1.50	1.31		1.31
4	1.30	1.22		1.22
5	1.30	1.18		1.18
6	1.30	1.17		1.17
7	1.30	1.18		1.18
8	1.30	1.25		1.25
9	1.40	1.34		1.34
10	1.60	1.50	0.080	1.58
11	1.70	1.64	0.080	1.72
12	1.33	1.74	0.080	1.82
13	1.33	1.88	0.080	1.96
14	1.47	2.03	0.080	2.11
15	1.54	2.15	0.080	2.23
16	1.61	2.20	0.080	2.28
17	1.61	2.22	0.080	2.30
18	1.61	2.33	0.080	2.41
19	1.68	2.38	0.080	2.46
20	1.68	2.31	0.080	2.39
21	2.47	2.22		2.22
22	2.58	2.34		2.34
23	2.47	2.24		2.24
24	2.15	1.87		1.87

} Adjustment Period

Hour 10 -  $1.60 - 1.50 = .1$

Hour 11 -  $1.70 - 1.64 = .06$


Adjustment -  $-.1 + .06 = .16/2 = .08$

# +90°F Average Day – Applying Adjusted Baseline to Demand Response




Hour	Actual Customer Load	Customer Load			Adjusted Baseline	Demand Response		
		10% Reduction	20% Reduction	30% Reduction		10% Reduction	20% Reduction	30% Reduction
1	1.70	1.70	1.70	1.70	1.56	0.14	0.14	0.14
2	1.60	1.60	1.60	1.60	1.45	0.15	0.15	0.15
3	1.50	1.50	1.50	1.50	1.31	0.19	0.19	0.19
4	1.30	1.30	1.30	1.30	1.22	0.08	0.08	0.08
5	1.30	1.30	1.30	1.30	1.18	0.12	0.12	0.12
6	1.30	1.30	1.30	1.30	1.17	0.13	0.13	0.13
7	1.30	1.30	1.30	1.30	1.18	0.12	0.12	0.12
8	1.30	1.30	1.30	1.30	1.25	0.05	0.05	0.05
9	1.40	1.40	1.40	1.40	1.34	0.06	0.06	0.06
10	1.60	1.60	1.60	1.60	1.58	0.02	0.02	0.02
11	1.70	1.70	1.70	1.70	1.72	(0.02)	(0.02)	(0.02)
12	1.90	1.71	1.52	1.33	1.82	(0.11)	(0.30)	(0.49)
13	1.90	1.71	1.52	1.33	1.96	(0.25)	(0.44)	(0.63)
14	2.10	1.89	1.68	1.47	2.11	(0.22)	(0.43)	(0.64)
15	2.20	1.98	1.76	1.54	2.23	(0.25)	(0.47)	(0.69)
16	2.30	2.07	1.84	1.61	2.28	(0.21)	(0.44)	(0.67)
17	2.30	2.07	1.84	1.61	2.30	(0.23)	(0.46)	(0.69)
18	2.30	2.07	1.84	1.61	2.41	(0.34)	(0.57)	(0.80)
19	2.40	2.16	1.92	1.68	2.46	(0.30)	(0.54)	(0.78)
20	2.40	2.16	1.92	1.68	2.39	(0.23)	(0.47)	(0.71)
21	2.30	2.30	2.42	2.47	2.22	0.08	0.19	0.25
22	2.40	2.40	2.52	2.58	2.34	0.06	0.18	0.24
23	2.30	2.30	2.42	2.47	2.24	0.06	0.18	0.23
24	2.00	2.00	2.10	2.15	1.87	0.13	0.23	0.28

# +90°F Average Day – Applying Adjusted Baseline to Demand Response



Demand Reduction Event Day  
+90°F Average Day Baseline Calculation w/ ISO New England Baseline Adjustment Rules



# Conclusions

- **Baselines created with different procedures**
- **ISO New England**
  - **Uncomplicated calculation**
  - **Adjustment provision**
  - **Baseline created every day**
- **New York ISO**
  - **Created only when needed**
  - **Adjustment provision**
  - **Complex multi-step process**



## Conclusions (cont'd)

- **California ISO**
  - Energy selection based
  - No adjustment provision yet
- **PJM**
  - Created only when needed
  - Adjustment provision
  - Complex multi-step process
- **+90°F Average Day**
  - Easy to understand process
  - Might not have enough days for accurate results